SOUTH PEKIN GRADE SCHOOL DISTRICT 137

Sample ID	Sample Location Discription	Fixture type	Sample Type	Concentration
SPGS01	1ST FLOOR HALL 108	FOUNTAIN	FIRST DRAW	<2.00 ppb
SPGS01	1ST FLOOR HALL 108	FOUNTAIN	FLUSH	<2.00 ppb
SPGS02	1ST FLOOR HALL 104	FOUNTAIN	FIRST DRAW	<2.00 ppb
SPGS02	1ST FLOOR HALL 104	FOUNTAIN	FLUSH	<2.00 ppb
SPGS03	KITCHEN 3 TUB	SINK	FIRST DRAW	2.41 ppb
SPGS03	KITCHEN 3 TUB	SINK	FLUSH	<2.00 ppb
SPGS04	STEAM KETTLE FILL	OTHER	FIRST DRAW	<2.00 ppb
SPGS04	STEAM KETTLE FILL	OTHER	FLUSH	2.18 ppb
SPGS05	OLD GYM	FOUNTAIN	FIRST DRAW	<2.00 ppb
SPGS05	OLD GYM	FOUNTAIN	FLUSH	<2.00 ppb
SPGS06	PE OFFICE	ICE MACHINE	FIRST DRAW	196 ppb
SPGS06	PE OFFICE	ICE MACHINE	FLUSH	12.0 ppb
SPGS07	2ND FLOOR HALL 206	FOUNTAIN	FIRST DRAW	<2.00 ppb
SPGS07	2ND FLOOR HALL 206	FOUNTAIN	FLUSH	<2.00 ppb
SPGS08	2ND FLOOR HALL 204	FOUNTAIN	FIRST DRAW	<2.00 ppb
SPGS08	2ND FLOOR HALL 204	FOUNTAIN	FLUSH	<2.00 ppb
SPGS09	KITCHEN DISHWASHER	OTHER	FIRST DRAW	11.2 ppb
SPGS09	KITCHEN DISHWASHER	OTHER	FLUSH	<2.00 ppb
SPGS10	MAIN OFFICE	ICE MACHINE	FIRST DRAW	<2.00 ppb
SPGS10	MAIN OFFICE	ICE MACHINE	FLUSH	<2.00 ppb